

**OFFICE OF ASSISTANT ENGINEER,
P.H. SUB DIVISION, LALGANJ.**

Lt. No. 635 /Lalganj

Date: 16 / 06 /2025

TO WHOM IT MAY CONCERN

This is to certify that St. Joseph's Public School at Sarai, District Vaishali Bihar, on the basis of inspection and Water Test Report (Attached) vide Lt. No. 08 Dt 30.05.2025 of Chemist Sub Divisional Lab Lalganj, has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State Govt.

This above is valid for a period of one Year.

July
16/06/2025
J.C. Bhagwanpur

Shalini
16/6/25

Set No:- 08

Date - 30/05/2025

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

Zone: Muzaffarpur				District: Vaishali		Sub-Division: Talgaonj		Month		May 2025												
Sl. No.	Block	Panchayat	Village	Habitation	Location Details	Type of source (HP- lift- III/Ord. PWS- Stand/PWS House connection)	Physico-Chemical & Bacteriological parameters															
							pH	Conductivity (µs/cm)	TDS	Turb.	Total Hardness (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Alkalinity (mg/L)	Chloride (mg/L)	Nitrate (mg/L)	Iron (mg/L)	Sulphate (mg/L)	Fluoride (mg/L)	Arsenic (mg/L)	Total Coliform (MPN/100 ml)	Remarks (safe / unsafe)
1	2	3	4	5		7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	Bhagwanpur	Sarai	Sarai	Sarai	ST. JOSEPH'S PUBLIC SCHOOL		7.32	225	146	1	96	30.4	4.8	98	16							
Desirable limit							6.5-8.5		500	1	200	75	30	200	250	45	0.3	200	1.0	0.01		
Permissible limit in absence of alternate source							NR	--	2000	5	600	200	100	600	1000	No relaxatio	1.0	400	1.5	NR		Should not be detected in 100 ml sample

NOTE: 1. Bold with underline or Highlight the parameter if the result is beyond permissible limit. 2. Under remarks (safe/unsafe) column, unsafe sources should be bold with underline or to be highlighted 3. BDL-Below Detection Limit

P. K. Singh
30/05/2025

SD
Chemist/Assistant

Date:

